

certificate

The applicant: **RECUPERACION DE MATERIALES TEXTILES,
S.A.**

1.Can Magre c/Joan Guell Narcis Monturiol
08187 STA. EULALIA DE ROÇANA - BARCELONA

is authorized to place the label " Certificate of Reaction to Fire of
Construction Products" according to the report Nº 2009AN7807



aitex

**CERTIFICATE OF FIRE
BEHAVIOUR OF:**

CONSTRUCTION PRODUCTS



Nº 09AN7807

The thermal insulation gamma for wallcovering and ceiling referenced
as

"NITA-COTON-FRP"

has been tested according to the standards UNE-EN ISO 11925-2:2002
(equivalent to EN ISO 11925-2:2002) and UNE-EN 13823:2002 (equivalent
to EN 13823:2002). The classification according to standard UNE-EN
13501-1:2007 (equivalent to EN 13501-1:2007) is:

"B_{s2,d0}"



certificate



The applicant: **RECUPERACION DE MATERIALES TEXTILES,
S.A.**

I. Can Magre c/Juan Guell Narcis Monturiol
08187 STA. EULALIA DE ROÇANA - BARCELONA


**CERTIFICATE OF FIRE
BEHAVIOUR OF:
CONSTRUCTION PRODUCTS**

Nº 09AN7807


The gamma is formed by the articles referenced:

- Density 15 Kg/m³ for a minimum thickness of 100mm and maximum of 200mm (insufflate).
- Density 38 Kg/m³ for a minimum thickness of 40mm and maximum of 200mm (pressure injected)

This certificate has validity until October 28th 2014
Alcoy, October 29th 2009



Jordi Fernàndez Pascual
HEAD OF FIRE DEPARTMENT



Raquel Muñoz González
CHIEF OF LABORATORIES AREA